

§ 145.10

33 CFR Ch. I (7-1-97 Edition)

TABLE 145.05(c)—PORTABLE AND SEMI-PORTABLE EXTINGUISHERS

| Classification | | Soda-acid and water, gallons | Foam, gallons | Carbon dioxide, pounds | Dry chemical, pounds |
|----------------|----------|------------------------------|---------------|------------------------|----------------------|
| Type | Size | | | | |
| A | II | 2½ | 2½ | | |
| B | II | | 2½ | 15 | 10 |
| C | II | | | 15 | 10 |
| B | V | | 40 | 100 | 50 |

(d) All portable and semi-portable extinguishers shall have permanently attached thereto a durable name plate giving the name of the item, the rated

capacity in gallons or pounds, the name and address of the person or firm for whom approved, and the identifying mark of the actual manufacturer.

[CGFR 56-4, 21 FR 903, Feb. 9, 1956, as amended by CGFR 58-28, 23 FR 6880, Sept. 6, 1958]

§ 145.10 Locations and number of fire extinguishers required.

(a) Approved portable and semi-portable extinguishers shall be installed in accordance with Table 145.10(a).

(b) Semi-portable extinguishers shall be located in the open so as to be readily seen.

TABLE 145.10(a)—PORTABLE AND SEMI-PORTABLE EXTINGUISHERS

| Space | Classification | Quantity and location |
|--|---|--|
| SAFETY AREAS | | |
| Communicating corridors | A-II | 1 in each main corridor not more than 150 feet apart. (May be located in stairways.) |
| Radio room | C-II | 1 in vicinity of exit. |
| ACCOMMODATIONS | | |
| Sleeping accommodations | A-II | 1 in each sleeping accommodation space. (Where occupied by more than 4 persons.) |
| SERVICES SPACES | | |
| Galleys | B-II or C-II | 1 for each 2,500 square feet or fraction thereof for hazards involved. |
| Storerooms | A-II | 1 for each 2,500 square feet or fraction thereof located in vicinity of exits, either inside or outside of spaces. |
| MACHINERY SPACES | | |
| Gas-fired boilers | B-II (CO ₂ or dry chemical). | 2 required. |
| Gas-fired boilers | B-V | 1 required. ¹ |
| Oil-fired boilers | B-II | 2 required. |
| Oil-fired boilers | B-V | 2 required. ¹ |
| Internal combustion or gas turbine engines | B-II | 1 for each engine. ² |
| Electric motors or generators of open type | C-II | 1 for each 2 motors or generators. ³ |

¹ Not required where a fixed carbon dioxide system is installed.

² When installation is on weather deck or open to atmosphere at all times 1 B-II for each three engines is allowable.

³ Small electrical appliances, such as fans, etc., shall not be counted or used as basis for determining number of extinguishers required.

[CGFR 56-4, 21 FR 903, Feb. 9, 1956]

PART 146—OPERATIONS

Subpart B—Manned OCS Facilities

Subpart A—OCS Facilities

Sec.

- 146.1 Applicability.
- 146.5 Person in charge.
- 146.10 Notice of new facilities.
- 146.15 Maintenance of emergency equipment.
- 146.20 Work vests.
- 146.30 Notice of casualties.
- 146.35 Written report of casualty.
- 146.40 Diving casualties.
- 146.45 Pollution incidents.

- 146.101 Applicability.
- 146.105 General alarm system.
- 146.110 Emergency signals.
- 146.115 Duties of personnel during an emergency.
- 146.120 Manning of survival craft.
- 146.125 Emergency drills.
- 146.130 Station bill.
- 146.135 Markings for emergency equipment.
- 146.140 Emergency Evacuation Plan.

Subpart C—Mobile Offshore Drilling Units (MODUs)

- 146.201 Applicability.